WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29878
Permit No.
Basin 6-89

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9[illegible]

1. OWNER Charles Adams
MAILING ADDRESS 210 Esmeralda Drive, Carson City, Nevada
ADDRESS AT WELL LOCATION 235 Flaton, Carson City, Nevada

2. LOCATION NW ¼ NW ¼ Sec. 5 T. 16 N/S R. 19 E Washoe County
PERMIT NO. WCfy 3211 (Issued by Water Resources) | Parcel No. | New Washoe City (Subdivision Name)

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐ air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
D.G., Compacted		0	7	7
Granodiorite, medium to hard brown to tan color		7	36	29
White, to gray granite, Hard to very Hard One fracture at 122'-23' Making 2-3 GPM	✓	36	200	164
White-Blue Colored granite Very Hard, fine grained, solid to 334', small fractures to 355 No water in fractures		200	355	155
T.D. 355 FT				

RECEIVED APR 27 1988 STATE ENGINEER'S OFFICE

Date started April 5, 1988
Date completed April 12, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed with air-4 gravel packed			
Making 2-3 GPM from 300 FT			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 10 3/4 inches Total depth 355 feet
Casing record 6 5/8" Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 inches	+2 feet	355 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 3 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3
From 335 feet to 355 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 83 feet below land surface
Flow 2-3 G.P.M. ..... P.S.I.
Water temperature Cool ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co (Contractor)
Address 5554 Hiway 50 E #3 Carson City, Nevada (Contractor)
Nevada contractor's license number 23295
Nevada contractor's drillers number
Nevada driller's license number 1472 (Actual Driller)
Signed ..... (Contractor)
Date April 13, 1988

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434