WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29883
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9729

1. OWNER Pinetree Construction
MAILING ADDRESS Box 1261
Yerington Nevada
ADDRESS AT WELL LOCATION 2413 Centennial Dr
Genoa, Nevada

2. LOCATION SW ¼ SW ¼ Sec. 3 T. 13 N/S R. 19 E. Douglas County
PERMIT NO. (Issued by Water Resources) 17-012-17 (Parcel No.) None assigned (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	12	12
w/ boulders				
Loose tuffs		12	177	165
rock with				
small to medium				
boulders				
Grey badly	✓	177	165	28
fractured granite				
carrying water				
T.D. 165 ft				

RECEIVED
APR 27 1988
STATE ENGINEER'S OFFICE

Date started April 22, 19
Date completed April 26, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Removed mud with	Clean water		
& formed packed			
Blew bottom from	155'		
for best results to water			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 10¾ inches Total depth 165 feet
Casing record 6⅝ steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 inches	7.7 feet	165 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 165 feet

Perforations:
Type perforation Factory Mill-Slot
Size perforation 3/16 x 2½"
From 140 feet to 165 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 130 feet below land surface
Flow 15 G.P.M. ..... P.S.I.
Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A & H PUMP CO. (Contractor)
Address 5551 Hwy. 50 East #3, Carson City, Nevada 89701
883-0459 - 883-4023 (Contractor) 885-1889
Nevada contractor's license number 23295
Nevada contractor's drillers number
Nevada driller's license number 1472
Signed Quinton Butts (Actual Driller)
Contractor
Date April 27, 1988

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434