29926

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29926
Permit No.
Basin 6-87 Truckee Mead.

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9573

1. OWNER SIERRA MEADOWS CONSTR./LEIBOWITZ
MAILING ADDRESS 2615 Cactus View
Reno, NV 89506

ADDRESS AT WELL LOCATION 8555 Council Lane
Reno, NV 89511

2. LOCATION NW ¼ NW ¼ Sec. 12 T 18N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. SW Reno (Subdivision Name)

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ] Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders w/clay		0	22	22
Brown clay		22	25	3
Boulders w/sand		25	34	9
Volcanic sand & gravel w/clay streaks		34	58	24
Brown clay		58	64	6
Volcanic-cemented sand & grravel		64	69	5
Brown clay w//soft streaks		69	88	19
Volcanic black sand med.		88	101	13
Clay w/sand streaks		101	108	7
Sand, black volcanic (Fine)		108	117	9
Soft sandy clay		117	131	14
Brown clay		131	133	2
Boulders		133	134	1
Black sand	X	134	135	1
Brown clay		135	137	2
Brown clay		137	149	12
Brown sand	X	149	155	6
Brownclay		155	170	15
Soft zone		170	172	2
Clay		172	173	1
Brown sand	X	173	181	8
Clay		181	195	14

Date started 4-30-88, 19
Date completed 5-5-88, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 195 feet
inches
inches
Casing record 195' steel casing installed.
Weight per foot Thickness 50

Diameter	From	To
6 5/8 inches	0 feet	195 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type cement
Depth of seal 50 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 195 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 6 around
From 137 feet to 187 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level (0) Arteasian (25GPM) no pump feet below land surface
Flow 80+ G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date May 9, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627