

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 7431

PRINT OR TYPE ONLY

1. OWNER Willow Creek G.I.D. ADDRESS AT WELL LOCATION NONE
 MAILING ADDRESS 15 S MAIN Willow Creek Saver Ponds
YERINGTON NV 89447 3 Miles NW of Yerington Nevada
 2. LOCATION SE 1/4 SW 1/4 Sec 28 T 14 N/S R. 25 E Lyon County
 PERMIT NO. 8- 14-241-13 WILLOW CREEK G.I.D.
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE [Monitor]	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
20% sand 80% clay		0	5	
90% sand 10% clay		5	10	
100% sand	xx	10	14	
Course Gravel	xx	14	37	
Gray Clay		37	38	
Course Gravel	xx	38	53	
Brown Clay		53	60	T.D.
<u>Waiver issued 5-10-88</u>				

8. WELL CONSTRUCTION

Diameter 6 3/4 inches Total depth 60 feet
 inches
 inches
 Casing record 2" SCH 40 PVC
 Weight per foot _____ Thickness _____

Diameter	From	To
<u>2</u> inches	<u>-1</u> feet	<u>60' 57'</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Concrete
 Depth of seal 5' feet
 Gravel packed: Yes No
 Gravel packed from 5' feet to 60' 57' feet

Perforations:
 Type perforation Skill Saw
 Size perforation 1/8" x 5"
 From 10' 7' feet to 40' 37' feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level _____ feet below land surface
 Flow none G.P.M. none P.S.I.
 Water temperature cool °F Quality _____

Date started 5/11/88, 19_____
 Date completed 5/12/88, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Air
BAKER TEST

G.P.M. 10 Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Sierra Pump & Drilling Contractor
 Address P.O. Box 18507 Reno, Nevada Contractor
 Nevada contractor's license number issued by the State Contractor's Board 012236E
 Nevada contractor's driller's number issued by the Division of Water Resources 1393
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
 Signed Sierra Pump & Drilling
 By driller performing actual drilling on site or contractor
 Date 5/12/88