

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 9499

PRINT OR TYPE ONLY

1. OWNER Gene Rezentos ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P. O. Box 9844 3000 Yellowtail
Reno, Nv 89507
 2. LOCATION SW 1/4 SW 1/4 Sec 1 T 21 N/S R. 21 E Washoe County
 PERMIT NO. 077-190-01 - Palomino Valley Parcel # 11
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown & tan D.G. & clay		0	4	4
Brown & green broken & fractured volcanic rock		4	158	154
Brown green yellow white volcanic sands & gravels	218	158	238	80
238' T.D.				

'88 MAY 17 9 54
 STATE ENGINEERS OFFICE

8. 10" - 60" WELL CONSTRUCTION

Diameter 8 1/2 inches Total depth 237 feet

Casing record 6 5/8 inches
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+1 1/2</u> feet	<u>237</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type grout
 Depth of seal 53 feet
 Gravel packed: Yes No
 Gravel packed from 53 feet to 237 feet

Perforations:

Type perforation factory
 Size perforation 3/32 X 3
 From 217 feet to 237 feet
 From _____ feet to _____ feet

Date started 5/5/88, 19____
 Date completed 5/5/88, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean & develop.			

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 195 feet below land surface
 Flow 20+ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc.
 Address 625 Spice Islands Dr. Suite L Sparks, Nv 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada contractor's driller's number 1132
 issued by the Division of Water Resources
 Nevada driller's license number issued by the 1511
 Division of Water Resources, the on-site driller
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date 5/6/88