WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29930
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9930

1. OWNER Painter Construction
MAILING ADDRESS Box 1201
Zephyr Cove, Nevada

ADDRESS AT WELL LOCATION 2436 Jacks Valley Road
Genoa, Nevada Lot #3

2. LOCATION SW ¼ SW ¼ Sec. 3 T. 13 N/S R. 19 E. Douglas County

PERMIT NO. ..... Issued by Water Resources | 17-072-15 Parcel No. | none Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden with boulders and talus rock		0	11	11
Loose, hard talus rock, interspersed with boulders, very abrasive		11	130	119
broken granite small amount of water	✓	119	128	9
Hard, course granite with fractures. Carrying water	✓	128	160	32
T.D. 160 Feet				

Date started April 27, 1988
Date completed May 2, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

'88 MAY 18 A11:03 RECEIVED STATE ENGINEERS OFFICE

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 10 3/4 to 60 inches Total depth 160 feet
Casing record 6 5/8 O.D. Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+ 2 feet	160 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 160 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3" X 3/32"
From 133 feet to 153 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 123 feet below land surface
Flow 16-18 G.P.M. ..... P.S.I.
Water temperature Cold °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO. 5551 Hwy. 50 East #3 Carson City, Nevada 89701 883-0459 - 883-4023 885-1889 Contractor
Address ..... Contractor
Nevada contractor's license number 23295
Nevada contractor's drillers number .....
Nevada driller's license number 1472 Actual Driller
Signed Painter R Butt Contractor
Date May 2, 1988

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434