WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29937
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 7732

1. OWNER (Blades Const) Lance Madinpacher
MAILING ADDRESS 2267 Main
Genoa, Nevada

ADDRESS AT WELL LOCATION Lot #2
2415 Centennial Drive
Genoa, Nevada

2. LOCATION SW ¼ SW ¼ Sec. 3 T. 13 N/S R. 19 E. Douglas County
PERMIT NO. ____ Issued by Water Resources | 17-072-16 Parcel No. | None Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ boulders and broken talus rock		0	20	20
Talus rock, very hard and loose. Hard drilling		20	134	124
Clay seam		134	136	2
Compacted, highly fractured talus very hard with small amounts of water to bottom		136	180	44
T.D. 180 Feet				

88 MAY 19 A11:03
RECEIVED
STATE ENGINEER'S OFFICE

Date started May 3, 1988
Date completed May 9, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed mud from well and developed well with 250 psi air for 4 hours from 170 feet		12 GPM	

BAILER TEST

G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION

Diameter 10 3/4 to 60 inches Total depth 180 feet
9 3/4 inches
____ inches
Casing record 6 5/8 Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	180 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 180 feet

Perforations:
Type perforation Factory Mill slot
Size perforation 3" x 3/32"
From 155 feet to 175 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL

Static water level 127 feet below land surface
Flow 12 G.P.M. ____ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A & H Pump Co
Contractor
Address 5331 Howard St. #3 Carson City, Nev 89701
Contractor

Nevada contractor's license number issued by the State Contractor's Board 23295

Nevada contractor's driller's number issued by the Division of Water Resources ____

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 11472

Signed Clinton Butler
By driller performing actual drilling on site or contractor

Date May 11, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627