WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29938
Permit No.
Basin 6-90
NOTICE OF INTENT NO. 2921

PRINT OR TYPE ONLY

1. OWNER Wayne Pim, Sr.
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1806 U.S. Hiway 50 S Lake Tahoe, NV
Doc 81677 Book 1280 Pg 1056

2. LOCATION NE ¼ SW ¼ Sec. 15 T. 14 N/S R. 18 E. Douglas County
PERMIT NO. RPA 624-87 (Issued by Water Resources) 01-110-13 (Parcel No.) Whispering Pines (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden, sand		0	6	6
Sand, gravel, soft to hard		6	43	37
D.G. Composted to hard		43	97	54
Granite, course grading to fine grained, white & grey coloring with fractures carrying water	✓	97	140	43
T.D. 140 FT				

MAY 18 1988 11:03 STATE ENGINEERS OFFICE

Date started May 10, 1988
Date completed May 12, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed well to remove drill mud. Developed with air & gravel packed during development			
Blowing 50 GPM from 85'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 3/4 60' inches Total depth 140 feet
8 3/4 inches
inches
Casing record 6 5/8" steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2- feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Bentonite
Depth of seal 100 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 100 feet to 140 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3
From 100 feet to 140 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 28 feet below land surface
Flow 50+ G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co. (Contractor)
Address 5334 Hwy 50 Carson City, NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 5/16/88

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627