

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 8972

PRINT OR TYPE ONLY

1. OWNER James Baker ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3382 York Ln _____
Fallon, NV. 89406 _____
 2. LOCATION SW 1/4 SW 1/4 Sec 8 T 18 OS R. 28 E Churchill County _____
 PERMIT NO. none Issued by Water Resources _____ Parcel No. _____
06-291-61 Subdivision Name Oren Hampton Paul Map 15-62-87

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Overburden</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>Clay + Sand Brown</u>		<u>5</u>	<u>20</u>	<u>15</u>
<u>Clay Brown</u>		<u>20</u>	<u>32</u>	<u>12</u>
<u>Clay gray</u>		<u>32</u>	<u>38</u>	<u>6</u>
<u>Clay + Sand brown</u>		<u>38</u>	<u>55</u>	<u>17</u>
<u>Course Brown Sand 6'-6"</u>		<u>55</u>	<u>60</u>	<u>5</u>
<u>Clay-gray Cemental</u>		<u>60</u>		

MAY 18 AM 11:18
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Diameter 6 inches Total depth 60 feet
 _____ inches
 _____ inches
 Casing record Steel
 Weight per foot 17.02 Thickness 1.250
 Diameter From To
6 inches +18" feet 60 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type Heat
 Depth of seal 25 feet
 Gravel packed: Yes No
 Gravel packed from 59 feet to 60 feet
 Perforations:
 Type perforation Touch
 Size perforation 5/32 x 4"
 From 57 feet to 60 feet
 From _____ feet to _____ feet

Date started 5-12 1988
 Date completed 5-13 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>3600</u>	<u>13 1/2</u>	<u>37'-6"</u>	<u>4</u>

Sol Pump at 55'
Use 10 gpm flow control
Don't pump over 13 1/2 gpm.

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL
 Static water level 6'-6" feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Excellent

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Water-Rite Well Drilling
 Address P.O. Box 883 Fallon, NV. 89406
 Nevada contractor's license number issued by the State Contractor's Board 0023978
 Nevada contractor's driller's number issued by the Division of Water Resources 1473
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1473
 Signed Harold W. Olson
 By driller performing actual drilling on site or contractor
 Date 5-14-88