

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 9504

PRINT OR TYPE ONLY

1. OWNER Harry Linnecke ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 3310 Davis Lane 3310 Davis Lane
Reno, Nv 89511

2. LOCATION 1/4 NW 1/4 Sec 1 T 18 N/S R. 19 E Washoe County _____
PERMIT NO. 40-572-25 - _____
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
New Well Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock

5. TYPE WELL
Cable Rotary
Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay yellow				
brown red & tan volcanic rock		0	18	18
purple yellow & brown volcanic rock		18	40	22
Green purple & gray cobbles & boulders		40	110	70
Orange purple green yellow volcanic rocks and sands		110	130	20
Gray black white granite hard		130	147	17
Reddish cinder clay with coarse gray green white black sands & gravels		147	182	35
yellow gray clay with yellow red & white sand gravels		182	278	96
Brown yellow white green coarse sands & gravels		278	301	23

Date started 5/17/88, 19_____
Date completed 5/20/88, 19_____
Date started _____, 19_____
Date completed _____, 19_____

8. 12 1/4" - 60' WELL CONSTRUCTION
Diameter 10 5/8 inches Total depth 301 feet
9 7/8 inches
inches
Casing record 8 5/8
Weight per foot 16.94 Thickness .188

Diameter	From	To
<u>8 5/8</u> inches	<u>+1 1/2</u> feet	<u>301</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type neat cement
Depth of seal 52 feet
Gravel packed: Yes No
Gravel packed from 52 feet to 301 feet

Perforations:
Type perforation factory
Size perforation 3/32 X 3 1 double 1 single
From Double 264 feet to 284 feet
From Single 184 feet to 204 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

9. WATER LEVEL
Static water level 80 feet below land surface
Flow 40+ G.P.M. _____ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AQUA DRILLING & WELL SERVICE, INC.
Address 625 Spice Islands Dr. Suite L Sparks, Nv
89431
Nevada contractor's license number issued by the State Contractor's Board 15291
Nevada contractor's driller's number issued by the Division of Water Resources 1132
Nevada driller's license number issued by the Division of Water Resources 1511
Signed Roger M. Thrall
By driller performing actual drilling on site or contractor
Date Roger M. Thrall

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours