

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9816

1. OWNER Andrew Sayre ADDRESS AT WELL LOCATION Smith Nevada
MAILING ADDRESS Smith Nevada 89430
2. LOCATION NE 1/4 NE 1/4 Sec. 26 T. 11 N. R. 23 E. Lyon County
PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision _____

3. TYPE OF WORK
New Well Recondition
Deepen Other
4. PROPOSED USE
Domestic Irrigation
Municipal Industrial
5. TYPE WELL
Cable Rotary
Other Stock Test

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Topsoil		0	12	12
Gravel	Yes	12	24	12
Sandy clay		24	40	16
Sand		40	112	72
Gray clay		112	156	44
Blue clay		156	170	14
Gravel	Yes	170	190	20
Brown, sandy clay		190	198	8

JUN +2 9:47
STAVE ENGINEERS OFFICE

8. WELL CONSTRUCTION
Diameter 0 inches Total depth 198 feet
Casing record 198
Weight per foot _____ Thickness 250
Diameter _____ From _____ To _____
Surface seal: Yes No Type Concrete
Depth of seal 50 feet
Gravel packed: Yes No
Perforations:
Type perforation Torch cut
Size perforation 3/32" x 5"
From 180 feet to 195 feet

Date started 5-18-88, 1988
Date completed 5-30-88, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
Static water level 20 feet below land surface
Flow _____ G.P.M. _____ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EMDL CO. INC Contractor
Address Box 92, Smith, NV 89430
Nevada contractor's license number 24149 issued by the State Contractor's Board
Nevada contractor's driller's number 718 issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Milly
By driller performing actual drilling on site or contractor
Date 6-1-88

BAILER TEST
G.P.M. 20 Draw down 10 feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours