WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 29987
Permit No.
Basin 8-102

NOTICE OF INTENT NO. 5784

1. OWNER DANIAL LISEK
MAILING ADDRESS P.O. BOX 337
SILVER SPRINGS, NV. 89429

ADDRESS AT WELL LOCATION 3250 S.
S.T. SILVER SPRINGS, NV.

2. LOCATION SE ¼ SW ¼ Sec. 9 T. 17 N/S R. 25 E. LYON County
PERMIT NO. (Issued by Water Resources) 17-174-12 (Parcel No.) LAKE SIDE SUB. #2 (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND + CLAY (MIX)		0	7	7
SAND + CLAY (STRATA)		7	30	23
C. SAND		30	50	20
BLUE CLAY		50	65	15
BLUE CLAY + SAND		65	70	5
BLUE CLAY		70	85	15
BROWN CLAY		85	110	25
COARSE SAND		110	115	5
COARSE SAND + GRAVEL		115	120	5
SAND, GRAVEL, BROWN CLAY		120	123	3
BROWN CLAY		123	127	4
BLUE CLAY		127	150	23
BROWN CLAY + SAND	X	150	165	15
COARSE SAND + GRAVEL	X	165	175	10

Date started 4-18, 1988
Date completed 4-25, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3450	22	1.5'	1 HR.

BAILER TEST
G.P.M. 25 Draw down 2 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 3/8 inches Total depth 176' feet
Casing record
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	(+) 1 feet	175' feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type GROUT
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50' feet to 175' feet

Perforations:
Type perforation SAWED
Size perforation 3/32" x 3" x 6 ROWS
From 155 feet to 175 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 29' 6" feet below land surface
Flow G.P.M. P.S.I.
Water temperature COLD °F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name OGDEN BROS DRILLING (Contractor)
Address 162 N. BYBEE RD. YERINGTON, NV. 89447 (Contractor)
Nevada contractor's license number 15646
Nevada contractor's drillers number 640 & 870
Nevada driller's license number 640 (Actual Driller)
Signed Billy Ogden (Contractor)
Date 5-9-88

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434