WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

SECTION 14bba

PRINT OR TYPE ONLY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29988
Permit No.
Basin 8-105

I

NOTICE OF INTENT NO. 6603

1. OWNER Tony Debono
MAILING ADDRESS 350 Ashton St
Milbrae, Calif.

ADDRESS AT WELL LOCATION 3375 Bernese Court

2. LOCATION NE ¼ NW ¼ Sec. 14 T. ~~13~~ T.14N. N/S R. 19 E. Douglas County

PERMIT NO. ..... Issued by Water Resources | 15-101-11 Parcel No. | Alpine View Estates #3 Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden dirt & small rock		0	9	9
Tight Clay w/ small gravels		9	93	84
Gravels changing to dogs	–	93	97	4
Fractured granite with water	–	97	120	23
T.D. 120				
Had to drill last 25 feet with drill mud to hold gravels in place				

Date started May 17, 1988
Date completed May 19, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed well with air to gravel pack & remove drill mud. Making 25+ GPM from 100' w/ 250 psi air @ 450 CFM			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 3/4 to 60 inches Total depth 120 feet
8 1/2 inches
..... inches
Casing record 6 5/8" O.D. Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 120 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3
From 100 feet to 120 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 35 feet below land surface
Flow 25+ G.P.M. ..... P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name P&H Pump Co
Contractor
Address 5551 Newbury St. Carson City, NV
Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed Stanley R Butts
By driller performing actual drilling on site or contractor
Date May 21, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627