WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29989
Permit No.
Basin 8-105

NOTICE OF INTENT NO. 1997

PRINT OR TYPE ONLY

1. OWNER J & D Construction
MAILING ADDRESS 1360 Porter Lane
Minden, Nevada
ADDRESS AT WELL LOCATION 845 Rubio
Gardnerville Nevada

2. LOCATION NW ¼ SE ¼ Sec. 11 T. 12 N S R. 20 E. Douglas County
PERMIT NO. (Issued by Water Resources) 27-663-05 (Parcel No.) Chambers Field (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden with Rocks Sand & Clay		0	9	9
Rock to 4" diameter with fine to course Sand	✓	9	87	78
Course Gravels with Sand	✓	87	120	33
Five foot blank on bottom of Casing string				
T.D. 120 FT				

STATE ENGINEERS OFFICE RECEIVED JUN -2 '88

Date started May 25, 19 88
Date completed May 26, 19 88

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed mud with Clean water & gravel packed			
Blew 30-40 GPM from 100 ft with hot pressure air			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 inches Total depth 120 feet
..... inches
..... inches
Casing record 6 5/8 Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 120 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3
From 95 feet to 115 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 16 feet below land surface
Flow 30+ G.P.M. ..... P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co Contractor #3
Address 555 Hwy 50 Carson City, NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 472
Signed Clinton Britts (By driller performing actual drilling on site or contractor)
Date May 27, 1987

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627