WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30047
Permit No.
Basin 89. WASHOE V.

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10308

1. OWNER JOYCE BARKUS
MAILING ADDRESS 713 N Walsh, Apt. #2
Carson City, NV 89710

ADDRESS AT WELL LOCATION
3290 Nye Drive
Carcon City, Nv 89710

2. LOCATION NE ¼ SE ¼ Sec. 6 T. 16 N/S R. 20 E. Washoe County
PERMIT NO. (Issued by Water Resources) 50-464-06 (Parcel No.) Washoe Valley (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy clay		0	7	7
Brown sand		7	30	23
Black sandy clay		30	33	3
Brown coarse sand		33	45	12
Small gravel		45	54	9
Brown clay		54	61	7
Sand & gravel cemented with clay		61	71	10
Clay		71	78	7
Sand, brown		78	82	4
Clay		82	97	15
Sand gray	X	97	102	5
Clay gray		102	106	4
Sand gray	X	106	121	15
Clay blue		121	128	7
Sand w/clay streaks	X	128	144	16
Hard rock & gravel		144	on	

Date started 6-8-88, 19
Date completed 6-9-88, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 144 feet
inches
inches
Casing record 144' steel casing installed.
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	144 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 144 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 6 around
From 110 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 20 feet below land surface
Flow 40+ G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed [signature] (By driller performing actual drilling on site or contractor)
Date June 9, 1988

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 11-85) (O)-627