WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30119
Permit No.
Basin 6-84

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10300

1. OWNER WARREN & ELYCIA DECKER
MAILING ADDRESS 455 Curnow Canyon
Reno, Nv. 89510

ADDRESS AT WELL LOCATION Same

2. LOCATION SE 1/4 NW 1/4 Sec. 5 T. 21 N/S R. 21 E. Washoe County

PERMIT NO. (Issued by Water Resources) | 76-190-07 (Parcel No.) | Palomino Valley (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil & blow sand		0	13	13
Weathered granite (hard)		13	61	48
Soft zone		61	62	1
Weathered granite (hard)		62	142	80
Soft zone		142	143	1
Weathered granite (hard)		143	210	57
Soft zone (no water)		210	211	1
Weathered granite (hard)		211	286	75
White fine grained hard granite		286	404	118
Small fracture (no water)		404	406	2
White granite		406	490	84
Weathered granite (Hard)		490	532	42
White granite		532	544	12
Soft zone (no water)		544	566	22
Weathered granite		566	587	15
Soft zone (3GPM)	X	587	598	11
Weathered granite		598	620	22
Soft zone	X	620	623	3
Weathered granite		623	650	27

Date started 6-27-88, 19
Date completed 6-30-88, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 650 feet
inches
inches
Casing record 650' steel casing installed
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	650 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 650 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 6 around
From 592 feet to 642 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 495 feet below land surface
Flow 13 ½ G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 Reno, NV. 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] By driller performing actual drilling on site or contractor
Date June 30, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627