WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 36153
Permit No.
Basin 92 B LEMMON V. east

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9574

1. OWNER JERRY & MAGGIE O'DOAN
MAILING ADDRESS 3275 Warpaint
Reno, Nv. 89506

ADDRESS AT WELL LOCATION Same

2. LOCATION NW ¼, NW ¼ Sec. 11 T. 20 N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 83-176-03 (Parcel No.) Golden Valley (Subdivision Name)

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☒ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Air

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| deepening | | | | |
| Weathered granite | | 143 | 145 | 2 |
| Soft zone | X | 145 | 147 | 2 |
| Weathered granite | | 147 | 155 | 8 |
| Brown soft sandy clay | | 155 | 165 | 10 |
| Weathered granite | | 165 | 174 | 9 |
| Soft zone | X | 174 | 179 | 5 |
| Weathered granite | | 179 | 200 | 21 |

Date started 7-21-88, 19
Date completed 7-21-88, 19

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 200 feet
inches
inches
Casing record: 200' steel casing installed
Weight per foot Thickness .156

| Diameter | From | To |
|---|---|---|
| 6 5/8 inches | 0 feet | 200 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☐ No ☒ Type
Depth of seal feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 130 feet to 200 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 6 around
From 140 feet to 160 feet
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 102 feet below land surface
Flow 25 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. Box 12370 Reno, Nv. 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date July 21, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (09-027)

'88 JUL 26 P1:55

RECEIVED
STATE ENGINEERS OFFICE