WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30155
Permit No.
Basin 105 CARSON VALLEY

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10887

1. OWNER Greg Davies Construction
MAILING ADDRESS P.O Box 22
Gardnerville, Nevada
ADDRESS AT WELL LOCATION 1051 Tenaba St
Gardnerville Nevada

2. LOCATION NE ¼ SE ¼ Sec 12 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. 23-232-07 Issued by Water Resources (new apn # 1220-12-710-038) Parcel No. Pine Nut Manor Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	6	6
Pea gravels Cemented w/heavy Clay Seams		6	184	178
Gravels, fine to Course w/ Sand 2-3 GPM @ 190-192,	✓	184	218	34
Major Water Course from 211-218	✓			
Clay, tight		218	220	2
T.D. 220 Ft				

1051 Tenaba Ln
Old APN 23-232-07
~~New APN~~
~~1220-12-710-038~~
Legal
NW SE Sec 12 12N 20E

Date started July 18, 1988
Date completed July 21, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed well with air & gravel packed			
18-20 GPM from 210 ft			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 3/4 to 60 inches Total depth 220 feet
8 1/2 inches
inches
Casing record 6 5/8" steel
Weight per foot 14.7 Thickness .156

Diameter	From	To
6 inches	+2 feet	220 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 220 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3
From 200 feet to 220 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 180 feet below land surface
Flow 18-20 G.P.M. ..... P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H&H Pump Co. Contractor
Address 555 Highway 50 East Carson City, NV Contractor
Nevada contractor's license number issued by the State Contractor's Board 23095
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 14-92
Signed [signature] By driller performing actual drilling on site or contractor
Date July 22, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627