WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30177
Permit No.
Basin 8-105

CDAD

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10853

1. OWNER John Hutin
MAILING ADDRESS 865 Folsom CT
Minden Nevada

ADDRESS AT WELL LOCATION 3639 Summer Hill drive
Minden, Nevada

2. LOCATION NE ¼ SE ¼ Sec. 6 T. 14 N/S R. 20 E. Douglas County
PERMIT NO. — Issued by Water Resources
13-103-06 Parcel No.
NoNE Jacks Valley Area Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ D. G, loose		0	5	5
D. G. Semi-Compacted, tan to brown		5	58	53
Soft D.G, mining		58	62	4
Granodiorite, medium hard to hard, H2O @ 131' 2GPM	✓	62	131	59
Granodiorite, hard, fine to Course, white, fractured, carrying water	✓	131	200	69
Major water courses from 189'-194'				
T.D. 200 Ft				

Date started 7/28, 1986
Date completed 8/2, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Used Air, Clean, Gravel pack and developed 25+ GPM from 180 Using 450 CFM Air			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11 1/2 to 60' inches Total depth 200 feet
8 1/2 inches
inches
Casing record 6 5/8" Steel
Weight per foot 11.7 Thickness .188

Diameter	From	To
6 inches	+2 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 200 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 180 feet to 200 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 167 feet below land surface
Flow 25+ G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H pump Co. Contractor
Address Carson City, NV 89701 Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1450
Signed [signature] By driller performing actual drilling on site or contractor
Date Aug 2, 1986

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627