



**WELL DRILLERS REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 7302

1. OWNER Jim Delaney ADDRESS AT WELL LOCATION 3615 Mark Lane  
Winnevucca, NV. 89445

2. LOCATION N/W 1/4 S/W 1/4 Sec. 10 T. 37 N/S R. 38 E Humboldt County  
 PERMIT NO. "NA" 06-481-13 Delaney Subdivision  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	3	3
Lava Rock		3	50	47
Gravel w/ clay		50	110	60
5 ft. fill in				
788 OCT 25 10:09 STATE ENGINEERS OFFICE				

8. WELL CONSTRUCTION  
 Diameter hole 6 1/2 inches Total depth 110 feet  
 Casing record 105 feet  
 Weight per foot: \_\_\_\_\_ Thickness 15 lb  

Diameter	From	To
<u>6 1/2</u> inches	<u>0</u> feet	<u>105</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Concrete  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 105 feet  
 Perforations:  
 Type perforation mill slot  
 Size perforation 1/8 in.  
 From 84 feet to 105 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 40 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Larry Brinkerhoff Contractor  
 Address P.O. Box 1878 Winnevucca, NV. 89445 Contractor  
 Nevada contractor's license number 0020578  
 Nevada contractor's drillers number 1161  
 Nevada driller's license number 730 Actual Driller

Signed Gerald La Mott Contractor  
 Date October 21, 1988

Date started October 9, 1988  
 Date completed October 10, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>15</u>		

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

