WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

DCDA

PRINT OR TYPE ONLY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30632
Permit No.
Basin 6-88

NOTICE OF INTENT NO. 17877

1. OWNER Miles Bros Const
MAILING ADDRESS P.O. Box 209 Minden Nevada
ADDRESS AT WELL LOCATION 4760 Toiyabe Road Reno Nevada

2. LOCATION SW ¼ SE ¼ Sec. 2 T. 45-67-73 N/S R. 19 E. Douglas County
PERMIT NO. ~~[illegible]~~ Issued by Water Resources | Parcel No. | Subdivision Name: Old Walena Tourist

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand + Cobbles		0	19	19
Sand w/ Cobbles and Clay		19'	79'	60
Cobbles + Gravel Carrying water		79'	110'	31
Blue Granite		110'	120'	10

Date started Nov 14 1988
Date completed Nov 14 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Develope w/ air + Bailed			
Perfed			
Not Metered	20-25		
			GPM

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 3/4 inches Total depth 120' feet
..... inches
..... inches
Casing record 6 5/8 Steel
Weight per foot ..... Thickness 188

Diameter	From	To
6 inches	0 feet	80 feet
..... inches	110 feet	120' feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet

Surface seal: Yes ☑ No ☐ Type .....
Depth of seal 51 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 51 feet to 120 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 - 3"
From 80 feet to 110 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 53 feet below land surface
Flow 0 G.P.M. 20-25 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A + H Pump Co. (Contractor)
Address 5551 Highway 50 E. Carson City (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1472
Signed Clinton R. Bates (By driller performing actual drilling on site or contractor)
Date Nov 14 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627