WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30638
Permit No.
Basin 8-101

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 11993

1. OWNER Don Travis
MAILING ADDRESS 1800 Wade Ln. Fallon, NV. 89406
ADDRESS AT WELL LOCATION 1950 Wade Ln. Fallon, NV. 89406

2. LOCATION NW ¼ SW ¼ Sec. 13 T 19 N S R 28 E Churchill County
PERMIT NO. ..... Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☒ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse brown sand				
clay mixed		35	38	3'
Cemented gravel				
(gray)		38	39	1'
Course gray				
Sand		39	46	7'
Black Clay		46	48	2'
Fine gray sand				
(Water Black)		48	57	9'
Course gray				
Sand clay mixed		57	63	6'
gray quick sand		63	73	10'
Brown Clay		73	74	1'
Brown sand				
Course fines mixed		74	76	2'
Brown gravel				
Course Sand mixed	X	76	80	2'

Well was 8" to 35'
deepened to 80' with 6"

Date started Nov. 11, 1988
Date completed Nov. 13, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3600	23	~~[illegible]~~ 27'-6"	2½ hours
(Do	NOT Exceed		20GPM.

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 80' feet
..... inches
..... inches
Casing record 82'-9¾"
Weight per foot 17.02 Thickness .250

Diameter	From	To
6 inches	+2'-9¾" feet	80 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

~~Surface seal~~: Yes ☐ No ☐ Type .....
~~Depth of seal~~ ..... feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 79 feet to 80 feet

Perforations:
Type perforation Torch Cut
Size perforation 5/32 by 4"
From 77 feet to 80 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 8'-5" feet below land surface
Flow ~~[illegible]~~ ~~G.P.M.~~ ~~P.S.I.~~
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Water-Rite Well Drilling (Contractor)
Address 3400 Bottom Rd. Sp. 3 Fallon, NV. 89406 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0023978
Nevada contractor's driller's number issued by the Division of Water Resources 1525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1525
Signed Sam Olson
By driller performing actual drilling on site or contractor
Date Nov. 14, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627