

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 11686

1. OWNER MARIE WALTON ADDRESS AT WELL LOCATION 2195 OLD RIVER ROAD
 MAILING ADDRESS 100 BENCH ROAD FALLON, NV
FALLON, NV 89406
 2. LOCATION NE 1/4 SE 1/4 Sec. 18 T. 19 N. R. 29 E. CHURCHILL County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	2	2
CLAY		2	12	10
SAND		12	19	7
CLAY		19	23	4
SAND	X	23	34	11
BLACK CLAY & SILT		34	76	42'
COARSE SAND & GRAVEL	X	76	90	14
CLAY		90		

8. WELL CONSTRUCTION

Diameter 6 5/8 inches Total depth 90 feet

Casing record 6 5/8 X 90

Weight per foot 12.9 Thickness 1.88

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>90</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type CEMENT

Depth of seal 50 feet

Gravel packed: Yes No

Gravel packed from _____ feet to _____ feet

Perforations:

Type perforation MACHINE SLOT

Size perforation 3/32 X 3

From 80 feet to 88 feet

From _____ feet to _____ feet

Date started NOVEMBER 10 19 88
 Date completed NOVEMBER 11 19 88

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>AIR BLOWN @ 25 GPM</u>			

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours

G.P.M. _____ Draw down _____ feet _____ hours

G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 12 feet below land surface

Flow _____ G.P.M. _____ P.S.I.

Water temperature 61 °F Quality UNKWN

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP.

Address P. O. BOX 888 FALLON, NV 89406

Nevada contractor's license number 11752 issued by the State Contractor's Board

Nevada contractor's driller's number 772 issued by the Division of Water Resources

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562

Signed [Signature]
 By driller performing actual drilling on site or contractor

Date 11-18-88