

Log No. 31024  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5817

1. OWNER Don Ander ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 9190 NEV. 82001

2. LOCATION S/W  $\frac{1}{4}$  S/W  $\frac{1}{4}$  Sec. 29 T. 6S N/S R. 6E E. Lincoln County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	25	25'
sand - Gravel		25	45	20
clay - sand		45	60	15
gravel - boulders	X	60	80	20
fractured rock		80	85	5
consolidated gravel		85	90	5
Brown clay		90	100	10

8. WELL CONSTRUCTION

Diameter 12 1/4 inches Total depth 100 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches

Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 188

Diameter	From	To
<u>8 7/8</u> inches	<u>0</u> feet	<u>100</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Cement  
 Depth of seal \_\_\_\_\_ feet  
 Gravel packed: Yes  No   
 Gravel packed from 60' feet to 100' feet

Perforations:  
 Type perforation factory  
 Size perforation 1/8 x 3  
 From 60' feet to 100' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 SEP 2 1988  
 Division of Water Resources  
 Branch Office - Las Vegas, NV

Date started 8-30, 1988  
 Date completed 9-2, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>air test</u>	<u>25</u>	<u>2</u>	<u>1 hr</u>
_____	_____	_____	_____
_____	_____	_____	_____

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL

Static water level 6' feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality poor

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name AAA Drilling Contractor  
 Address Box 70 Panaca NEV Contractor

Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada contractor's driller's number issued by the Division of Water Resources 20684  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191  
 Signed Mike J Davis  
 By driller performing actual drilling on site or contractor

