WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

In Book

OFFICE USE ONLY
Log No. 31029
Permit No. 52045
Basin 228

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1712

1. OWNER Beatty Power & Water
MAILING ADDRESS Beatty Nevada
ADDRESS AT WELL LOCATION Same

2. LOCATION SE ¼ NW ¼ Sec. 2 T. 12 N/S R. 46 E. NYE County
PERMIT NO. 52045 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cemented Gravel		0	40	40
Alluvium		40	70	30
Red Clay		70	120	50
Tuff Gray	X	120	270	150
Welded Tuff	X	270	320	50
Fractured Tuff	X	320	700	380

RECEIVED
JAN 17 1989
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 12-20, 1988
Date completed 1-15, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Air Lift	225	179	7

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 15" inches Total depth 700 feet
..... inches
..... inches
Casing record 10 3/4
Weight per foot ..... Thickness .250

Diameter	From	To
10 3/4 inches	+1 feet	700 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 0-65 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 65 feet to 700 feet
Perforations: Johnson Screen HICAP/100 SLOT
Type perforation Factory Cut
Size perforation 1/8 x 20 Row
From 240 feet to 700 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 130 feet below land surface
Flow 400 G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Water Well Services (Contractor)
Address 3365 W. Patrick Lane, Las Vegas NV. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0022311
Nevada contractor's driller's number issued by the Division of Water Resources 694
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1559
Signed [illegible] (By driller performing actual drilling on site or contractor)
Date 1-15-89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627