WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31037
Permit No.
Basin 230

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4055

1. OWNER US Ecology Inc
MAILING ADDRESS PO Box 578 Beatty Nev 89003

ADDRESS AT WELL LOCATION Spring

2. LOCATION NW ¼ NE ¼ Sec 35 T 13S N/S R 47 E Nye County
PERMIT NO Under Waiver 309 (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE monitoring
Domestic ☐ Irrigation ☐ Test ☑
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loose Sand + Gravel		0	17	17
Sand Sand + Gravel		17	201	184
Fine Sand Gravel, Silt		201	306	105
Fine Sand Silt + Gravel	306		326	20

RECEIVED
OCT 24 1988
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started Sept 7, 1988
Date completed Oct 19, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼" inches Total depth 325.9 feet
inches
inches
Casing record Mild + Stainless Steel
Weight per foot 22 Lbs Thickness .250

Diameter	From	To	
6 inches	2.5 Above Ground feet	260.9 feet	Mild
6 inches	260.9 feet	300.9 feet	Stainless
6 inches	320.9 feet	325.9 feet	
inches	feet	feet	
inches	feet	feet	
inches	feet	feet	

Surface seal: Yes ☑ No ☐ Type Cement Grout
Depth of seal 298 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 298 feet to 321 feet

Perforations:
Type perforation Stainless Steel Screen
Size perforation .40"
From 300.9 feet to 320.9 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 305.9 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 20 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cook Drilling Co (Contractor)
Address Rt 15 Box 543 Amargosa Valley Nev. 89020 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 5376A
Nevada contractor's driller's number issued by the Division of Water Resources C23
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 830
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Oct 26 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627