

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5796

1. OWNER USE Ecology Inc ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS PO Box 579 BEATTY NEV 89003 SIME

2. LOCATION NW 1/4 NE 3.5 T 13.5 N/S R 47 E NYE County \_\_\_\_\_  
 PERMIT NO. UNDER WAIVER 317 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE Monitoring  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Loose Sand &amp; GRAVEL</u>		<u>0</u>	<u>18</u>	<u>18</u>
<u>Sand &amp; GRAVEL</u>		<u>18</u>	<u>196</u>	<u>178</u>
<u>Loose Sand</u>		<u>196</u>	<u>208</u>	<u>12</u>
<u>Sand &amp; GRAVEL Silted</u>		<u>208</u>	<u>307</u>	<u>99</u>
<u>Sand GRAVEL &amp; TRAC Clay</u>	<u>307</u>		<u>326.4</u>	<u>19.4</u>

8. WELL CONSTRUCTION  
 Diameter 12 1/4" inches Total depth 326.4 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record STAINLESS + MILD STEEL  
 Weight per foot 22 lbs Thickness .250  
 Diameter From To  
6 inches 2.5 Above Ground feet 261.4 feet Mild Steel  
6 inches 261.5 feet 301.4 feet Stainless  
6 inches 321.4 feet 326.4 feet "  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type CEMENT GROUT  
 Depth of seal 298 feet  
 Gravel packed: Yes  No   
 Gravel packed from 298 feet to 322 feet  
 Perforations:  
 Type perforation STAINLESS STEEL SCREEN  
 Size perforation .40"  
 From 301.4 feet to 321.4 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED

OCT 26 1988

Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started Oct 11 1988  
 Date completed Oct 18 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 306.4 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 70 °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name COOK DRILLING Co Contractor  
 Address RT 15 Box 543 Pahrump Valley Nev 89020 Contractor  
 Nevada contractor's license number 5376 A issued by the State Contractor's Board  
 Nevada contractor's driller's number 623 issued by the Division of Water Resources  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 930  
 Signed Corey Can By driller performing actual drilling on site or contractor  
 Date Oct 26 1988