



PRINT OR TYPE ONLY

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 2483

1. OWNER KEN WEST ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____

2. LOCATION NW 1/4 SE 1/4 Sec 6 T 21 N/S R 59 E CLARK County _____

PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND & ROCK		0	47	47
SANDY RED CLAY		47	134	87
RED CLAY GRAVEL		134	224	90
RED CLAY		224	248	24
RED CLAY GRAVEL	X	248	260	12
RED CLAY SANDSTONE		260	312	52
RED SANDSTONE	X	312	317	5
LIME	X	317	350	33

8. WELL CONSTRUCTION

Diameter 10" inches Total depth 350 feet

Casing record 6-5/8 inches

Weight per foot _____ Thickness 156

Diameter	From	To
<u>6-5/8</u> inches	<u>0</u> feet	<u>350</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type CEMENT

Depth of seal 50" feet

Gravel packed: Yes No

Gravel packed from _____ feet to _____ feet

Perforations:

Type perforation TORCH - SLOT

Size perforation 1/16" X 6" X 4 AROUND

From 200 feet to 350 feet

From _____ feet to _____ feet

RECEIVED
 SEP 6 1988
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 8-20-88 1988
 Date completed 8-25-88 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>air</u>	<u>20</u>	<u>?</u>	<u>2</u>
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL

Static water level 122 feet below land surface

Flow _____ G.P.M. _____ P.S.I.

Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name FRED B. ALLEN IV Contractor

Address 4847 S. VALLEY VIEW BLVD Contractor

Nevada contractor's license number issued by the State Contractor's Board 0018917

Nevada contractor's driller's number issued by the Division of Water Resources 1301

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1376

Signed Fred B. Allen IV
 By driller performing actual drilling on site or contractor

Date Sept 1, 88

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____