



Log No. 31054  
 Permit No. \_\_\_\_\_  
 Basin. 212

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 11189  
2070 CALICO DR.

1. OWNER First Federal Savings ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NE 1/4 SW 1/4 Sec 6 T. 21S N/S R. 59 E Clark County  
 PERMIT NO. 1164-06-301-010 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_

3. TYPE OF WORK PROPOSED USE 5. TYPE WELL  
 New Well  Recondition  Domestic  Irrigation  Test  Cable  Rotary   
 Deepen  Other  Municipal  Industrial  Stock  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Red sand & silt		0'	8'	8'
Red sand clay		8'	160'	152'
Red sand stone		160'	195'	35'
Red clay		195'	205'	10'
Brown silty clay		205'	210'	5'
Red silt		210'	220'	10'
Sandy clay st.		220'	245'	25'
Hard Red clay		245'	250'	5'

*Handwritten notes:*  
 GWMP-14289  
 2070 CALICO DR.

RECEIVED  
 NOV 14 1988  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 7-23- 1988  
 Date completed 7-30- 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

8. WELL CONSTRUCTION

Diameter 12 1/4 inches Total depth 250 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 156  
 Diameter \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_  
8 5/8 inches 21 feet 250 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type Cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 250 feet

Perforations:  
 Type perforation factory  
 Size perforation \_\_\_\_\_  
 From 200 feet to 250 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level 68 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WALTER DALLING Contractor  
 Address 4375 N. FLORIDA Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0016696  
 Nevada contractor's driller's number issued by the Division of Water Resources N-A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 643  
 Signed Walter Dalling  
 By driller performing actual drilling on site or contractor  
 Date 11-9-88