


WELL DRILLERS REPORT

Please complete this form in its entirety



PRINT OR TYPE ONLY

OWNER LEE ATKINS ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____

2. LOCATION SW 1/4 SE 1/4 Sec. 22 T. 19 N/S R. 60 E CLARK County

PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		200	360	
CLAY & WATER		360	420	
NOTE: PULLED OUT ORIGINAL CASING AND DRILLED OUT OLD SEAL AND RECEMENTED TO 100 FEET.				
<i>Drilled out with 1 3/4 B.T</i>				
<i>Cement seal 4" x 100 ft.</i>				
RECEIVED				
OCT 21 1988				
Div. of Water Resources Branch Office - Las Vegas, NV				

Date started OCTOBER 5, 1988, 19_____
 Date completed OCTOBER 8, 88, 19_____
 7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

8. BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

8. WELL CONSTRUCTION

Diameter hole 7 7/8 inches Total depth 420 feet
 Casing record 6 5/8
 Weight per foot _____ Thickness 1.56

Diameter	From	To
<u>6 5/8</u> inches	<u>±1</u> feet	<u>420</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Cement
 Depth of seal 100 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation FACTORY 4 ROW
 Size perforation 3/16
 From 360 feet to 400 feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 110 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name VERNON H. DIMICK
 Contractor
 Address 5530 S. EVALINE ST.
 Contractor
 Nevada contractor's license number 10062
 Nevada contractor's drillers number 552
 Nevada driller's license number 552
 Actual Driller
 Signed V. H. Dimick
 Contractor
 Date OCTOBER, 19, 88

