WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

CDB

PRINT OR TYPE ONLY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE
Log No. 31080
Permit No. ~~51594~~ 62062
Basin 13-217 LVAB

NOTICE OF INTENT NO. 5059

1. OWNER Michael Delfante
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION ~~NW~~ SE ¼ SW ¼ Sec. 15 T. 19 N. R. 60 E. CLARK County
PERMIT NO. ~~51594~~ Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Clay & gravel | | 0 | 50 | |
| Clay | | 50 | 400 | |

RECEIVED
NOV 01 1988
Div. of Water Resources
Branch Office Las Vegas, NV
'90 JUN 13 P4:34
RECEIVED
STATE ENGINEERS OFFICE

Date started 10-5, 1988
Date completed 10-28, 1988

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 1/4 inches Total depth 400 feet
Casing record 0 - 400
Weight per foot ..... Thickness 1/8"

| Diameter | From | To |
|---|---|---|
| 8 inches | 0 feet | 400 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☑ No ☐ Type CONST. CEMENT
Depth of seal 0-50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 400 feet

Perforations:
Type perforation Acetylene
Size perforation 1/8 X 6"
From 200 feet to 400 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 180 feet below land surface
Flow Good G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Robert G. Wickoff
Contractor
Address 7340 W. Lone Mtn. Rd. L.V. NV. 89129
Contractor
Nevada contractor's license number 12866
Nevada contractor's drillers number 721
Nevada driller's license number 721
Actual Driller
Signed Robert G. Wickoff
Contractor
Date 10-29-88

(Rev. 6-81)

USE ADDITIONAL SHEETS IF NECESSARY

O-627 CR434