WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31166
Permit No.
Basin 8-101

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12239

1. OWNER KEN CLOSSER
MAILING ADDRESS 1594 WAINWRIGHT
SAN LEANDRO, CA 94571

ADDRESS AT WELL LOCATION 2650 HARRIGAN ROAD
FALLON, NV 89406

2. LOCATION NE ¼ SE ¼ Sec. 7 T. 18 N/S R. 29 E CHURCHILL County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	1	1
CLAY		1	11	10
SAND	X	11	13	2
CLAY		13	21	8
SAND	X	21	34	13
CLAY		34	37	3
BLACK CLAY & SILT	X	37	65	28
GRAY SAND		65	67	2
GRAY CLAY		67	99	32
CLAY		99	105	6
SAND & GRAVEL	X	105	124	19
CLAY		124		

'89 FEB 13 A11:01
STATE ENGINEER'S OFFICE

Date started JANUARY 31, 1989
Date completed FEBRUARY 1, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN @ 50 GPM			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 124 feet
..... inches
..... inches
Casing record 6 5/8 X 124
Weight per foot 12.9 Thickness .188

Diameter	From	To
6 inches	0 feet	124 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation MACHINE SLOT
Size perforation 3/32 X 3
From 115 feet to 122 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 10 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 60 °F Quality UNKWN

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (Contractor)
Address P. O. BOX 888 FALLON, NV 89406 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada contractor's driller's number issued by the Division of Water Resources 772
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562
Signed [signature] (By driller performing actual drilling on site or contractor)
Date FEBRUARY 9, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627