

OFFICE USE ONLY  
 Log No. 31202  
 Permit No. \_\_\_\_\_  
 Basin. 10-1376

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5120

1. OWNER Darren Jackson ADDRESS AT WELL LOCATION Santa Rosa Court  
 MAILING ADDRESS Beaumont Nevada

2. LOCATION N 1/4 SE 1/4 Sec 4 T. 10 N. R. 43 E. Nye County  
 PERMIT NO. 1 FILE # 205969  
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Clay		0	9	9
SAND		9	10	1
Brown Clay		10	12	2
GRAVEL		12	18	6
Grey Clay		18	19	1
GRAVEL		19	25	6
Brown Clay		25	46	21
SAND		46	47	1
GRAVEL		47	65	19
grey clay		65	67	2
GRAVEL		67	76	9
Brown Clay		76	90	14
GRAVEL		90	134	44
Brown Clay		134	135	1

89 MAR 24 9:46  
 RECEIVED  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Diameter 1 1/2 inches Total depth 135 feet  
9 1/2 inches  
 \_\_\_\_\_ inches  
 Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 1.50  

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>135</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type ASBESTOS CEMENT  
 Depth of seal 578 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation slotted  
 Size perforation 1/8" x 3'  
 From 95 feet to 128 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 3-17, 1981  
 Date completed 3-21, 1981

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

7 in lift

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL  
 Static water level 7 feet below land surface  
 Flow 100 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60 °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Waytek Drilling Co. Contractor  
 Address (460) Maynard Sparks NV Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 24521  
 Nevada contractor's driller's number issued by the Division of Water Resources 1374  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442  
 Signed Chris Waytek  
 By driller performing actual drilling on site or contractor  
 Date 3-21-81