WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31222
Permit No.
Basin 9-108

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12083

1. OWNER Indian Health Services
MAILING ADDRESS Reno District Office
206 B Cal Lane Sparks, NV 89431

ADDRESS AT WELL LOCATION Campbell Ranch

2. LOCATION NW ¼ NE ¼ Sec. 20 T. 14 N/S R. 25 E Lyon County

PERMIT NO. NA (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [ ]
Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	3	3
Sandy Clay		3	8	5
Sand		8	50	42
Coarse sand w/s trace of clay 2%		50	80	30
Clay		80	92	12
Sand and clay stringers		92	140	48
Sand w/s trace of clay		140	180	40
Clay and sand stringers		180	200	20

'89 MAR 15 A9:42
STATE ENGINEER'S OFFICE

Date started 1/9, 19 89
Date completed 1/11, 19 89

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	625	55'	50

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 14" inches Total depth 200 feet
..... inches
..... inches
Casing record 8"
Weight per foot ..... Thickness .....

Diameter	From	To
8" Blank inches	0 feet	105 feet
8" Screen inches	105 feet	120 feet
8" Blank inches	120 feet	150 feet
8" Screen inches	150 feet	170 feet
8" Blank inches	170 feet	180 feet
8" Screen inches	180 feet	190 feet

Surface seal: Yes [X] No [ ] Type Concrete
Depth of seal 4' to 57' feet
Gravel packed: Yes [ ] No [ ]
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation .....
Size perforation .....
From 8" Blank w/s feet to ..... feet
From 2' concrete plug feet to 190 to 195 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 24' feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Company, Inc. (Contractor)
Address P.O. Box 592 Winnemucca, NV 89445 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada contractor's driller's number issued by the Division of Water Resources C-23
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1448
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 3/10/89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627