

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5017

1. OWNER Richard Guelich III ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 66689 _____
Scotts Valley, CA. 95066 _____
 2. LOCATION SE 1/4 SW 1/4 Sec. 10 T. 14 N. R. 43 E Nye County
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Clay		0	10	
sd.		10	13	
Grey Clay		13	17	
crse sd.		17	18	
Brn Clay		18	32	
crse sd.		32	34	
Brn Clay		34	53	
crse sd.		53	59	
Brn. Clay		59	65	
crse sd.		65	68	
green clay		68	76	
Very crse sd	-	76	80	4
white /quartz like				
Brown Clay		80	83	
Small gravel	-	83	100	17

MAR -9 1989
 STATE ENGINEERS (P) 1

8. WELL CONSTRUCTION

Diameter 11 inches Total depth 100 feet
9 1/2 inches
 _____ inches

Casing record _____
 Weight per foot _____ Thickness _____

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>100</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type NEAT CEMENT
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 100 feet

Perforations:
 Type perforation slotted
 Size perforation 1/8 x 3/8
 From 75 feet to 100 feet
 From _____ feet to _____ feet

Date started 3-2, 1989
 Date completed 3-4, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level Artesian flow feet below land surface
 Flow 75 G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Waytek Drilling Co. Contractor
 Address 4662 MAYNARD Sparks, NV. Contractor 89433
 Nevada contractor's license number issued by the State Contractor's Board 024521
 Nevada contractor's driller's number issued by the Division of Water Resources 01374
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
 Signed Ken Waytek By driller performing actual drilling on site or contractor
 Date 3-4-89