

OFFICE USE ONLY
 Log No. 31224
 Permit No. _____
 Basin 8-104

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 11947

PRINT OR TYPE ONLY

1. OWNER Tim Terry ADDRESS AT WELL LOCATION 3749 Kings Canyon Rd
 MAILING ADDRESS P. O. Box 3223
Carson City, Nv 89702
 2. LOCATION NE 1/4 NE 1/4 Sec 23 T. 15 N/S R. 19 E Carson County
 PERMIT NO. 7-072-17 Of parcel 1158
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Granite boulders with black silty sands		0	12	12
Brown clay black green red yellow sands		12	89	77
Coarse sand brown clay with some gravels		85	110	25
Sticky brown clay with some sands & gravels		110	130	20
Sands & gravels with clay layers		130	165	35
Brown sticky clay		165	178	13
Green yellow white volcanic rock		178	215	37
Reddish brown clay yellow red white & green gravels		215	245	30
Gray pink yellow white & green sand and gravels		245	268	23
Green rock hard		268	273	5
T.D. 273'				

8. 10"-60" WELL CONSTRUCTION
 Diameter 8 1/2 inches Total depth 273 feet
6 inches
6 inches
 Casing record 6 5/8 inch & 5 inch
 Weight per foot 10.78 & 6.96 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+2</u> feet	<u>178</u> feet
<u>5</u> inches	<u>163</u> feet	<u>273</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type neat cement
 Depth of seal 52 feet
 Gravel packed: Yes No
 Gravel packed from 52 feet to 178 feet
 Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 138 feet to 158 feet
 From 243 feet to 263 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 3/21/89
 Date completed 3/23/89

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>17.6V</u>	<u>OC</u>	<u>68</u>	
<u>Blew with air to clean and develop.</u>			

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL
 Static water level 160 feet below land surface
 Flow 6 G.P.M. P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc.
Contractor
 Address 625 Spice Islands Dr Suite L Sparks, Nv
Contractor 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada contractor's driller's number 1132
 issued by the Division of Water Resources
 Nevada driller's license number issued by the 1511
 Division of Water Resources, the on-site driller
 Signed Roger M. Thrall
By driller performing actual drilling on site or contractor
 Date 3/28/89