

OFFICE USE ONLY
 Log No. 31225
 Permit No. _____
 Basin B-104

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 11636

PRINT OR TYPE ONLY

1. OWNER Sierra Pacific Power Co ADDRESS AT WELL LOCATION SPPCo
 MAILING ADDRESS Box 10100 875 E. Long St
Reno, NV 89520-0026 Carson City, Nevada
 2. LOCATION SW 1/4 SE 1/4 Sec 8 T 15 N 20 E County _____
 PERMIT NO. M10-125 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other hollow stem

6. SPC-4 LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
medium to coarse sand		4 1/2	6	
silty very fine sand		9 1/2	11	
fine sand and silts		13	14 1/2	
coarse sand - fine gravel		14 1/2	16	
clayey silty very fine sand		17	18 1/2	
fine sandy silt	x	19 1/2	21	
silty fine sand	x	24 1/2	26	
silty fine sand	x	30	35	

'89 MAR 16 10:18
 STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION

Diameter 10 inches Total depth 35 feet

Casing record PVC

Weight per foot _____ Thickness Sch 40

Diameter	From	To
<u>4</u> inches	<u>0</u> feet	<u>15</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement-bentonite

Depth of seal 13 ft feet

Gravel packed: Yes No

Gravel packed from 13 feet to 35 feet

Perforations:
 Type perforation manufactured slots
 Size perforation 0.020"

From 15 feet to 35 feet

From _____ feet to _____ feet

Date started 2-17-89, 19____
 Date completed 2-17-89, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

MAR 16 9:47 AM '89

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours

G.P.M. _____ Draw down _____ feet _____ hours

G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 20.08 feet below land surface

Flow _____ G.P.M. _____ P.S.I.

Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Paul A. Anderson Contractor

Address 1135 Bedford Rd. Reno Nev 89509 Contractor

Nevada contractor's license number issued by the State Contractor's Board _____

Nevada contractor's driller's number issued by the Division of Water Resources _____

Nevada driller's license number issued by the Division of Water Resources the on-site driller 1028

Signed Paul Anderson By driller performing actual drilling on site or contractor

Date _____