WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31289
Permit No. 17267
Basin 11-1892

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9012

1. OWNER TS Ranches
MAILING ADDRESS P.O. Box 3, Montello, Nevada 89830
ADDRESS AT WELL LOCATION Gambel Ranch, Montello, Nevada

2. LOCATION NE ¼ NE ¼ Sec. 27 T. 40 N/S R. 69 E. Elko County
PERMIT NO. 17267-replace (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay		0	3	3
gravel		3	25	22
dark grey clay & gravel		25	70	45
dark grey clay & silt		70	110	40
silt & course sand		110	114	4
fine gravel		114	138	24
partially cemented gravel		138	140	2
white clay		140	165	25
tan clay & sand		165	170	5

RECEIVED
STATE ENGINEERS OFFICE
'89 APR -3 AM 10:54

Date started February 20, 19 89
Date completed March 7, 19 89

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	2500	53	15½

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 27 inches Total depth 170 feet
..... inches
..... inches
Casing record 16" O.D. x 1/4 wall
Weight per foot 33.38 Thickness .....

Diameter	From	To
16 inches	+1 feet	170 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement grout
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 170 feet

Perforations:
Type perforation standard spacing
Size perforation 1/8"
From 100 feet to 150 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 1 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 59 °F Quality cloudy

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sargent Irrigation Company (Contractor)
Address P.O. Box 2646, Elko, Nv 89801 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 21246
Nevada contractor's driller's number issued by the Division of Water Resources 1391
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1493
Signed [signature] (By driller performing actual drilling on site or contractor)
Date March 31, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627