WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31295
Permit No.
Basin 163

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5532

1. OWNER ROBERT ~~LIMBAUGH~~ LIMBACH
MAILING ADDRESS P.O. Box 326
JEAN NEV 89019

ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ SW ¼ Sec. 26 T. 22 N/S R. 56 E. CLARK County
PERMIT NO. (Issued by Water Resources) 580-250-017 (Parcel No.) (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CALICHE		0	29	29
WHITE CLAY		29	33	4
BROWN SANDY CLAY		33	51	18
WHITE CLAY CONS		51	58	7
BROWN SANDY CLAY	WTR	58	60	2
CALICHE	WTR	60	61	1
CORAL		61	68	7
LT BROWN CLAY		68	72	4
CALICHE	WTR	72	80	8
LT BROWN CLAY		80	91	11
BROWN CLAY CONS		91	96	5
WHITE CLAY		96	107	11
BROWN CLAY		107	116	9
CALICHE	WTR	116	120	4

RECEIVED
APR 04 1989
Div. of Water Resources
Branch Office Las Vegas, NV

Date started 3-5, 1989
Date completed 3-12, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3450	25	4	1

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 14 inches Total depth 120 feet
..... inches
..... inches
Casing record
Weight per foot 12.5 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 60 feet to 120 feet

Perforations:
Type perforation FLAME CUT
Size perforation 3/8 X 4 4 Rows
From 90 feet to 120 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 54 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 66 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RCBB INC. (Contractor)
Address 1701 W CASIN BLVD. L.V. NV. 89102 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 020301
Nevada contractor's driller's number issued by the Division of Water Resources 1352
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1352
Signed Robert Laurlock (By driller performing actual drilling on site or contractor)
Date 4-2-89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627