WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
**DIVISION OF WATER RESOURCES**

# WELL DRILLER'S REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 31306
Permit No.
Basin 163

In Book

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5597.

1. OWNER John Ellenburg
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ SW ¼ Sec. 22 T. 24 N/S R. 56 E/W Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sandy top soil | | 0 | 6 | 6 |
| Brown Clay | | 6 | 98 | 92 |
| Brown Sand Stone | | 98 | 140 | 42. |

RECEIVED MAR 2 0 1989 Div. of Water Resources Branch Office - Las Vegas, NV

Date started 3-21, 19 89
Date completed 3-22, 19 89

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| Air developed 900 CFM | | | |
| 250 PSI @ 140 | | | |
| Approx 45 gpm | | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 ¼ inches Total depth 140 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness .156

| Diameter | From | To |
|---|---|---|
| 8 5/8 inches | 71 feet | 140 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50 feet feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Torch
Size perforation 1/4" x 8"
From 100 feet to 140 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 90 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature Cool °F Quality OK

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Mitchell Enterprises (Contractor)
Address 630 Rettig LV. NV. 89124. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 27030
Nevada contractor's driller's number issued by the Division of Water Resources 1475
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1475.
Signed Leon Mitchell (By driller performing actual drilling on site or contractor)
Date 3-27-89.

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627