

OFFICE USE ONLY  
 Log No. 21312  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 5782

PRINT OR TYPE ONLY

1. OWNER BRUCE STILES ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS Box 3302 \_\_\_\_\_  
LA HABRA, CAL. 90631 \_\_\_\_\_  
 2. LOCATION N.W. 1/4 N.W. 1/4 Sec 17 T. 20 S. R. 53 E. NYE County  
 PERMIT NO. \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name CAL VEGAS RANCHOS

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	1	1
HARD BROWN CLAY		1	4	3
BROWN CLAY		4	33	29
HARD BROWN CLAY		33	37	4
BROWN CLAY		37	42	5
BENTONITE CLAY		42	54	8
HARD BROWN CLAY		54	80	26
HARD BROWN CLAY		80	83	3
BROWN CLAY		83	94	11
HARD BROWN CLAY		94	97	3
BROWN CLAY		97	112	15
HARD BROWN CLAY		112	114	2
BROWN CLAY		114	123	9
HARD BROWN CLAY		123	136	13
BROWN CLAY		136	140	4

RECEIVED  
 MAR 24 1989  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION  
 Diameter 12 inches Total depth 140 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 140 FT. 8 5/8" O.D. STEEL  
 Weight per foot 14.11 Thickness .156  
 Diameter From To  
8 5/8 inches 0 feet 140 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type CEMENT  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation TORCH CUT  
 Size perforation 1/2" X 6"  
 From 80 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 2-28, 1989  
 Date completed 3-6, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 41 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name RON FLOYD PUMP & DRILLING  
 Address BOX 157 PAHRUMP, NEV.  
 Nevada contractor's license number issued by the State Contractor's Board 2479-A  
 Nevada contractor's driller's number issued by the Division of Water Resources 1424  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1427 - STAN HARDIN  
 Signed [Signature]  
 Date 3-14-89