WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31354
Permit No. 52760
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5622

OWNER KIMBERLY ~~Al~~ Rodrigues
MAILING ADDRESS 5274 Barbara Way
Las Vegas, NV 89119

ADDRESS AT WELL LOCATION
Arville & Ford

2. LOCATION NE ¼ SW ¼ Sec. 18 T 22 S R 61 E Clark County
PERMIT NO. ~~51951~~ 52760 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
QuasiMunicipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & gravel, some clay		0	80	80
Sand & grav, som clay & red sandstone		80	140	60
Sand & gravel		140	260	120
Sand, gravel,red clay		260	320	60
Sand & gravel		320	410	90

RECEIVED
MAR 20 1989
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started November 22, 1988
Date completed December 21, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 inches Total depth 410 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness .188

Diameter	From	To
8 inches	+1 feet	410 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 410 feet

Perforations:
Type perforation Mill slots
Size perforation 8 rows 1/8 x 2½ 6" centers
From 350 feet to 410 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 274 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMPSON DRILLING CO., INC. (Contractor)
Address 4185 W. Harmon Las Vegas, NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada contractor's driller's number issued by the Division of Water Resources 290
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1567
Signed Richard K. Thompson
By driller performing actual drilling on site of contractor
Date March 15, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627