WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31355
Permit No.
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 2806

1. OWNER Mr. & Mrs. Tom Hess
MAILING ADDRESS 390 E. Welpam Way
Las Vegas, NV

ADDRESS AT WELL LOCATION
390 E. Welpam Way

2. LOCATION NE ¼ SE ¼ Sec. 9 T. 23 S R. 61 E Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders & clay		0	60	60
white sandy clay		60	80	20
Wht. sandy clay, boulders		80	100	20
Clay & gravel		100	160	60
Wht. sandy clay & gravel		160	200	40
Brn. snady clay & gravel		200	280	80
Light clay & gravel		280	320	40
Gravel		320	340	20
Clay & gravel		340	360	20
Gravel		360	420	60
Red sandy clay & gravel		420	460	40
Gravel		460	480	20
Gravel & red clay		480	496	16

RECEIVED
MAR 31 1989
Div. of Water Res.
Carson City

Date started March 16, 1989
Date completed March 30, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 inches Total depth 496 feet
inches
inches
Casing record
Weight per foot Thickness .188

Diameter	From	To
8 inches	+ 1 feet	496 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 496 feet

Perforations:
Type perforation Mill slots
Size perforation 1/8 x 2½" 8 rows
From 375 feet to 476 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 300 feet below land surface
Flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMPSON DRILLING CO., INC. (Contractor)
Address 4185 W. Harmon Las Vegas, NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada contractor's driller's number issued by the Division of Water Resources 290
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1489
Signed Richard K. Thompson
By driller performing actual drilling on site or contractor
Date March 30, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627