WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31373
Permit No.
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 28059

1. OWNER Joe Brandise
MAILING ADDRESS c/o Brandise Construction
P.O. Box 28558, Las Vegas, NV 89102

ADDRESS AT WELL LOCATION
3620 Tobias

2. LOCATION SE SW ¼ NW ¼ Sec. 6 T. 22 S R. 62 E Clark County
PERMIT NO. / Issued by Water Resources | Parcel No. 178-06-202-928 | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	20	20
Sand & clay		20	60	40
Clay & graavel		60	80	20
White sandy clay		80	100	20
Clay		100	140	40
Clay & sand		140	180	40
Gravel & clay		180	300	120
Clay		300	360	60
Clay & sand		360	380	20
Gravel & clay		380	400	20

RECEIVED
MAR 31 1989
Div. of Water Resources
Branch Office - Las Vegas

Date started March 6, 1989
Date completed march 17, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 3/4 inches Total depth 400 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness .188

Diameter	From	To
8 inches	+1 feet	400 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 400 feet

Perforations:
Type perforation Mill slots
Size perforation 1/8 x 2½" 8 rows
From 200 feet to 300 feet
From 380 feet to 400 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 55 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 68 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMPSON DRILLING CO., INC. Contractor
Address 4185 W. Harmon Las Vegas, NV 89103 Contractor
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada contractor's driller's number issued by the Division of Water Resources 290
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1489
Signed Richard K. Thompson
By driller performing actual drilling on site or contractor
Date March 30, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627