WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31401
Permit No. 51752
Basin 08-105 Carson V.

PRINT OR TYPE ONLY

well #1

NOTICE OF INTENT NO. 12088

1. OWNER Pinenut Village
MAILING ADDRESS P.O. Box 2001
Minden, NV 89423

ADDRESS AT WELL LOCATION Gardnerville

2. LOCATION NE ¼ SE ¼ Sec. 2 T. 12 N/S R. 20 E Douglas County

PERMIT NO. 51752 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders w/s 30% clay		0	5	5
Boulders w/s 2% clay		5	60	55
Coarse sand & gravel w/s cobbles + 5% clay		60	130	70
Coarse sand & gravel w/s cobbles + 15% clay		130	150	20
Coarse sand & gravel w/s cobbles + 5% clay		150	210	60
Coarse sand & gravel w/s 20% clay		210	230	20
Coarse sand & gravel w/s 5% clay		230	305	75
Coarse sand & gravel w/s cobbles + 5% clay		305	400	95

RECEIVED AUG -8 '89 10:13 AM STATE ENGINEERS OFFICE

REVISED

Date started 3/15, 19 89
Date completed 3/31, 19 89

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	700	126	24

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 14 3/4 inches Total depth 400 feet
..... inches
..... inches
Casing record 10"
Weight per foot ..... Thickness .....

Diameter	From	To
10" Blank inches	0 feet	53 feet
10" Double inches	53 feet	400 feet
Row Perf inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 0-50 16" Conductor/Seal 0-50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 0 feet to 400 feet

Perforations:
Type perforation Mill Slot
Size perforation 1/8" X 2½"
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 93.96 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 61 °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address P.O. Box 592 Winnemucca, NV 89445 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada contractor's driller's number issued by the Division of Water Resources C-23
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1448
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 8/02/89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627