WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31406
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9705

1. OWNER Jose Garcia
MAILING ADDRESS Box 24 Bridgeport, Calif 93517
ADDRESS AT WELL LOCATION 626 Stage Coach Road Buchen Stroth Flats

2. LOCATION SE ¼ SE ¼ Sec. 24 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. None (Issued by Water Resources) 29-102-05 (Parcel No.) (Subdivision Name)

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	5	5
Highly Cemented gravels w/ fine Sand		5	87	82
Fine Sand & gravels Not highly Cemented		87	100	13
Cemented gravels with thin to thick Clay Seams, hard		100	210	110
Gravels, fine to Coarse, with Sand	✓	210	227	17
Hard Clay with Medium gravels		227	230	3
N 38.8836666 W 119.677537 NA027 Deepened under NOI 61947 T.D. 230'				

Date started April 24, 1989
Date completed April 27, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Gravel packed & developed with air. Blew GPM from 12-15 for 2 hours			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11¼ to 60' inches Total depth 230 feet
8½ inches
inches
Casing record 6⅝ O.D. Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6⅝ inches	+2 feet	230 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 55 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 55 feet to 230 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 210 feet to 230 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 180 feet below land surface
Flow 12-15 G.P.M. ..... P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A E H Pump Co (Contractor)
Address Carson City, NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed [signature] (By driller performing actual drilling on site or contractor)
Date April 27, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627