

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 12061

1. OWNER City of Carson ADDRESS AT WELL LOCATION East 5th street
MAILING ADDRESS Carson City, NV Carson City, NV

2. LOCATION NE 1/4 SE 1/4 Sec. 15 T. 15 (N/S R. 20 E Carson City County
PERMIT NO. N/A none none
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
New Well Recondition
Deepen Other

4. PROPOSED USE Monitor
Domestic Irrigation Test
Municipal Industrial Stock

5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay & Gravel		0	5	
Sand & Gravel		5	10	
Brown Clay		10	27	
Gravel		27	29	
Brown Sand		29	30	
Decomposed Granite		30	32	
Gray Clay		32	35	
Gravel		35	44	
Gray Clay		44	49	
White DG		49	60	
White Clay		60	66	
Decomposed Granite		66	70	
thin layers of cl & DG		70	80	
Green Sandy Clay		80	95	
Gray Clay		95	110	
White & Green DG		110	125	
Green Sandy Clay		125	140	
Green DG & Clay		140	150	
Green Sandy Clay		150	160	
Green Clay & DG		160	165	
White DG w/little Cl		165	185	
Brown Clay		185	195	
Multi-colored Clay		195	210	
Lavender Rock		210	220	
Multi-colored Rock		220	225	
Lt. Brown Cl & Rock		225	235	
Multi-colored Rock		235	244	

8. WELL CONSTRUCTION
Diameter 13 inches Total depth 20' feet
6 1/2 inches 245'
Casing record 20' Steel 245' PVC
Weight per foot _____ Thickness .188 & Sch 40
Diameter From To
8 inches 1 feet 20 feet
2 inches 0 feet 245 feet
Surface seal: Yes No Type Neat Cement
Depth of seal 0-150' feet
Gravel packed: Yes No
Gravel packed from 150' feet to 245' feet
Perforations:
Type perforation Mill Slot
Size perforation .030
From 160 feet to 190 feet
From 210 feet to 240 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Date started 1/3/89, 19_____
Date completed 1/20/89, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

air
BATER TEST
G.P.M. APPROX 10 Draw down 160 feet 8 hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
Static water level 18' feet below land surface
Flow none G.P.M. none P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Kimberly Builders Contractor
Address Reno, NV Contractor
Nevada contractor's license number issued by the State Contractor's Board 8595BC
Nevada contractor's driller's number issued by the Division of Water Resources N/A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
Signed Bruce Miller
By driller performing actual drilling on site or contractor
Date 1-25-89