WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 31427
Permit No.
Basin 6-89

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10596

1. OWNER Dr Ed Pierczynski
MAILING ADDRESS 940 N. Nevada
Carson City, NV

ADDRESS AT WELL LOCATION Lot #7
OFF FRANKTOWN ROAD
CARSON CITY, NV

2. LOCATION ~~NE NW~~ ¼ SW ¼ Sec. 22 T. 16 N S R. 19 E. Washoe County
PERMIT NO. ~~Wdy 3409~~ Issued by Water Resources | 55-190-08 Parcel No. | San Antonio Ranch Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ D.G.		0	2	2
Granodiorite, Soft to medium Hardness	✓	2	45	43
D.G. Fine to Medium Course, running		45	60	15
Granodiorite, White with brownish-tan Medium to Very hard fine to Course Grained		60	60	169
Granodiorite, Grey-white, Very hard w/ fractures Carrying water	✓	167	200	37
TD = 200 Ft				

Date started March 31, 1989
Date completed April 6, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with Clear water to gravel pack & replace drill Mud. Developed Well with air after Concrete Seal in place. 25-30 GPM from 160'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 1/4 inches Total depth 200 feet
..... inches
..... inches
Casing record 8 5/8" Steel
Weight per foot ..... Thickness .188

Diameter	From	To
8 5/8 inches	+2 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 200 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3
From 160 feet to 200 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 6 feet below land surface
Flow 25 G.P.M. ..... P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A&H pump Co
Contractor
Address Carson City, Nevada
Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed Quinton R Butts
By driller performing actual drilling on site or contractor
Date April 6, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627