WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 31498
Permit No.
Basin 4-49

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12399

1. OWNER PHILLIP & SUE EUDEY
MAILING ADDRESS P.O. Box 1304
Elko, NV 89801

ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ SE ¼ Sec. 3 T. 35 N/S R. 56 E. Elko County
PERMIT NO. (Issued by Water Resources) Lot 5 Blk 25 (Parcel No.) Meadow Valley Ranchos Unit #3 (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil | | 0' | 5' | 5' |
| Sandy Clay | | 5' | 18' | 13' |
| Sand w/some clay | | 18' | 25' | 7' |
| Sand & Gr. w/some clay | | 25' | 117' | 92' |

RECEIVED
STATE ENGINEERS OFFICE
APR -6 A9:14

Date started 3-10, 1989
Date completed 3-17, 1989

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| Blow Test | 10-12 gpm | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 117 feet
..... inches
..... inches
Casing record
Weight per foot 2.95# Thickness .188

| Diameter | From | To |
|---|---|---|
| 6 inches | +1½ feet | 96 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 117 feet

**Perforations:**
Type perforation Machine Slots
Size perforation 1/8" x 3"
From 96 feet to 117 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 20 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. Box 850 Elko, NV 89801 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada contractor's driller's number issued by the Division of Water Resources 1166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1166
Signed Dale C. Hackworth (By driller performing actual drilling on site or contractor)
Date 4-3-89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627