WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 31538
Permit No.
Basin 8-101

NOTICE OF INTENT NO. 4312

1. OWNER Mr. & Mrs. Henry Karau
MAILING ADDRESS 205 W. 7th
Sun Valley, NV 89433

ADDRESS AT WELL LOCATION 5241 ALCORN ROAD

2. LOCATION NE ¼ NE ¼ Sec. 32 T. 19 N/S R. 29 E Churchill County
PERMIT NO. ----- (Issued by Water Resources) 08-651-68 (Parcel No.) None (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sticky clay		0	17	17
fine sand		17	23	6
sandy clay		23	41	8
sand		41	44	3
toole mud		44	56	12
fine sand		56	58	2
toole mud		58	72	14
sand and coarse gravel (good)		72	81	9
toole mud		81	93	12
fine sand		93	94	1
toole mud		94	112	8
blue clay		112	114	2
fine sand		114	116	2
blue clay		116	120	4
fine sand (stink)		120	122	2
blue clay		122	123	1
coarse sand (stink)		123	126	3

STATE ENGINEERS OFFICE RECEIVED '89 APR -4 A9:33

Date started 3-8, 1989
Date completed 3-19, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1760	20	30	6

'89 APR 27 A9:46

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 126 feet
Casing record
Weight per foot ..... Thickness .188

Diameter	From	To
6 inches	-1 feet	81 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type neat cement
Depth of seal 50' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation torch cut
Size perforation 1/8 x 4"
From 77 feet to 81 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 12 feet below land surface
Flow ----- G.P.M. ----- P.S.I.
Water temperature ..... ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Potter Drilling Co. (Contractor)
Address P.O. Box 1815, Fallon, NV 89406 (Contractor)
Nevada contractor's license number 20161
Nevada contractor's drillers number 1348
Nevada driller's license number 1348 (Actual Driller)
Signed Jim Potter (Contractor)
Date 4-1-89

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434